

February 24, 2016

CITY OF MERCED
DEPARTMENT OF DEVELOPMENT SERVICES (ENGINEERING)
678 W. 18th Street, Merced, CA 95340

ADDENDUM NO. 1

To **ALL PROSPECTIVE BIDDERS**
under Specifications for the Construction of the

WASTEWATER TREATMENT PLANT NEW WELL CONSTRUCTION

PROJECT NUMBER 114001

For which bids are to be received by the City of Merced Purchasing Agent, at the Purchasing Conference Room, at 2525 "O" St., Merced, CA 95340, until 2:00 PM on Thursday, March 3, 2016.

The following revisions to the specifications and plans shall be made:

Item 1: Specification Section 332000 – Modify Paragraph 2.A.1.a as follows: "The outside diameter shall be 28 inches, the wall thickness shall be 5/16-inch, and the length shall be a minimum of 100-feet."

Item 2: Specification Section 332100 – Modify Paragraph 2.A.1 as follows: "The well casing shall be manufactured in accordance with the latest edition of ASTM A139, with the following conditions:"

Item 3: Specification Section 332100 – Modify Paragraph 2.A.1.a as follows: "The steel from which the casing is manufactured shall be ASTM A606, Grade 50 Type 4 low alloy, high strength steel."



Ken F. Elwin, P.E.
City Engineer

Name of Bidder or Firm: _____

THIS ADDENDUM MUST BE SIGNED AND RETURNED WITH BID PROPOSAL.

ADDENDUM NO. 1 has been received and incorporated into the bid proposal.

Received By: _____

Date : _____ Planholder : _____

NOTE: RECEIPT OF THIS ADDENDUM MUST ALSO BE ACKNOWLEDGED IN THE CONTRACTOR'S BID PROPOSAL.