

April 3, 2018

CITY OF MERCED
DEPARTMENT OF DEVELOPMENT SERVICES (ENGINEERING)
678 W. 18th Street, Merced, CA 95340

ADDENDUM NO. 1

To **ALL PROSPECTIVE BIDDERS**
under Specifications for the Construction of the
N STREET ROADWAY REHABILITATION
PROJECT NUMBERS 117041

For which bids are to be received by the City of Merced Purchasing Agent, at the Purchasing Conference Room, at 2525 "O" St., Merced, CA 95340, until 2:00 PM on **Tuesday, April 10, 2018.**

The following revisions to the specifications and plans shall be made:

Item 1: Specifications, Section **10-1.25 PULVERIZE EXISTING PAVEMENT** – **ADD** the text in red to the following paragraph:

REPAIR

"If the lime/cement stabilized subgrade is damaged, it shall be repaired by removing and replacing the entire depth of affected layers in the damaged area **with 3.5" asphalt concrete.** Feathering will not be permitted for repair of low areas.

Item 2: Specifications, Section **10-1.25 PULVERIZE EXISTING PAVEMENT** – **REMOVE** the text in red in the following paragraph:

MEASUREMENT AND PAYMENT

"The FDR of the existing pavement shall include costs for all pulverizing, and mixing of the existing pavement and underlying materials; for all water, High Calcium Quicklime, and Portland cement; for all spreading, compacting and trimming to the proper grade as shown on the plans and as specified; for all haul away of all excess pulverized material; for all micro-cracking, curing, protection and sealing of the stabilized subgrade. ~~Additional lime and/or cement and work required above and beyond the specified amount will be paid on a change order basis.~~"


Steven C. Son, P.E.
City Engineer

Name of Bidder or Firm: _____

THIS ADDENDUM MUST BE SIGNED AND RETURNED WITH BID PROPOSAL.

ADDENDUM NO. 1 has been received and incorporated into the bid proposal.

Received By: _____

Date : _____ Planholder : _____

NOTE: RECEIPT OF THIS ADDENDUM MUST ALSO BE ACKNOWLEDGED IN THE CONTRACTOR'S BID PROPOSAL.